



CSI: DIVISION: 22 00 00—PLUMBING
Section: 22 40 00—Facility Water Distribution
Section: 22 09 00—Instrumentation and Control for Plumbing

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: Backflow Preventers with an Intermediate Atmospheric Vent

Listee: CALEFFI North America, Inc.
3883 W. Milwaukee Road
Milwaukee, WI 53208
www.caleffi.us

Compliance with the following codes:

2021, 2018, 2015, 2012 and 2009 *International Plumbing Code*® (IPC)
2021, 2018, 2015, 2012 and 2009 *International Residential Code*® (IRC)
2021, 2018, 2015, 2012 and 2009 *Uniform Plumbing Code*® (UPC)*
* Copyrighted publication of the International Association of Plumbing and Mechanical Officials

Compliance with the following standards:

ASSE 1012-2021, Performance Requirements for Backflow Preventers with an Intermediate Atmospheric Vent

Identification:

Each device shall have the following information marked on it and all markings shall be visible after installation:

- a) The manufacturer's recognized name, trademark, or other mark; or
- b) Model number
- c) Maximum rated working pressure
- d) Maximum water temperature for which device is designed
- e) Serial number or other marking consistent with the manufacturer's standard practice
- f) Nominal valve size
- g) Direction of water flow through device
- h) The ICC-ES PMG listing mark

Markings shall be clear, permanent, and visible after installation.

Installation:

Products recognized in this listing shall be installed in accordance with the manufacturer's instructions and the applicable codes.

Models:

Model No.	Description
573403A	1/2" NPT female inlet/outlet
573409A	1/2" sweat inlet/outlet
573493A	1/2" sweat inlet x 1/2" FNPT outlet
573503A	3/4" NPT female inlet/outlet
573509A	3/4" sweat inlet/outlet

Conditions of listing:

1. The CALEFFI's products recognized in this listing must be installed in accordance with the manufacturer's published installation instructions and the applicable codes.
2. The CALEFFI's products recognized in this listing are manufactured under a quality control program with annual surveillance inspections by ICC-ES.